

TULBAGH WWTW - COMPLIANCE SUMMARY

PARAMETER	2009/2010	2010/2011	2011/2012	2012/2013	2013/2014	2014/2015	2015/2016	2016/2017
E.coli / Faecal Coli's	92	92	92	67	58	58	92	100
Ammonia	65	17	8	25	25	33	42	67
COD	92	92	75	50	58	25	67	83
Nitrates	75	100	100	83	75	100	92	92
Ortho Phosphates	75	100	100	92	100	100	100	100
pH	100	92	100	100	100	100	100	100
Electrical conductivity	100	100	100	100	100	100	100	100
Total suspended solids	100	100	100	100	83	42	67	58
MICRO	92	92	92	67	58	58	92	100
CHEMICAL = (A+C+N+O)/4	77	77	71	63	65	65	75	86
PHYSICAL = (P+E+S)/3	100	97	100	100	94	81	89	86
AVERAGE SCORE	90	89	88	77	72	68	85	91