

ODB WWTW														
PARAMETERS	GENERAL LIMITS	Jul-22	Aug-22	Sep-22	Oct-22	Nov-22	Dec-22	Jan-23	Feb-23	Mar-23	Apr-23	May-23	Jun-23	AVE 12 MONTHS
<b>MICROBIOLOGICAL</b>														
Faecal Colif0rms (org/100ml)	< 1000	38	461	62	1	65	<1	326	<1	34	147	2	387	
<b>COMPLIANCE PER MONTH</b>		100	100	100	100	100	100	100	100	100	100	100	100	
<b>AVERAGE COMPLIANCE</b>													100,00	
<b>PHYSICAL</b>														
pH	5.5 - 9.5	7,4	7,7	6,9	8,4	8,55	7,6	7,4	7,7	7,5	7,2	6,05	7	
Conductivity (at 25°C) (mS/m)	150	51	75,4	69,4	79	77,8	81,3	98,8	96,4	102	79,5	118	71	
TSS (mg/l)	25	10	38	19	18	13	17	21	25	18	22	13	51	
<b>COMPLIANCE PER MONTH</b>		100	67	100	100	100	100	100	100	100	100	100	67	
<b>AVERAGE COMPLIANCE</b>													94,50	
<b>CHEMICAL</b>														
COD (mg/l)	75	53	68,5	69,1	49	57,1	45,3	47,9	70,6	94	69,7	32,1	125	
Ammonia Nitrogen as N (mg/l)	6	0,19	11,7	0,39	0,39	1,5	12,4	32,8	52,6	45	33,7	2	13,1	
Nitrate Nitrogen as N (mg/l)	15	4,6	2,1	8,8	3,5	11,9	0,54	0,69	<0,2	<0,2	0,21	<0,2	7,1	
Ortho Phosphate as P (mg/l)	10	4,9	4,9	3	4,2	8,1	1,8	3,7	5,8	4,8	2,4	<0,2	3,2	
<b>COMPLIANCE PER MONTH</b>		100	75	100	100	100	75	75	75	50	75	100	75	
<b>AVERAGE COMPLIANCE</b>													83,33	
<b>OVERALL</b>		100	81	100	100	100	92	92	92	83	92	100	81	
<b>OVERALL COMPLIANCE FOR 2022/2023</b>														93